

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtl1@gmail.com



TC-14756

TEST REPORT

Name & Address of Customer : Shaheed Baba Deep Singh Public School Pahuwind , Tarn Taran		Customer Reference No.	No : 915/25 Dated : 25/04/2025
		Sample Submitted by	Mr. Ravinderbir singh
		Date of Sample Receipt	28/04/2025
		Analysis Starting Date	28/04/2025
		Analysis completion Date	29/04/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC147562500000142F	Sample Type :	Water
Test Report No.:	DWTLTT/2526/00043	Date of Issue :	30/04/2025
Registration no.:	DWTLTT/REG2526/00099	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / 350 ft
Village :	Pahuwind	Habitation :	Pahuwind
Block:	Bhikhi Wind	District :	Tarn Taran
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.89@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	237	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.10@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	220	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	156	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	27.25	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	21.38	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	15.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr.Mohammad Naushad Alam
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran

End of the Test Report